


CONCENTRIC(I)



ECCENTRIC(I)

KS B1541 / KS B1543, JIS B2312 / JIS B2313

Nominal Pipe Size	Outside Diameter		Wall Thickness T				
			Sch 5s		Sch 10s		S
	OD1	OD2	T1	T2	T1	T2	T1
25 x 20	34.0	27.2	1.65	1.65	2.8	2.1	3.0
25 x 15	34.0	21.7	1.65	1.65	2.8	2.1	3.0
32 x 25	42.7	34.0	1.65	1.65	2.8	2.8	3.0
32 x 20	42.7	27.2	1.65	1.65	2.8	2.1	3.0
40 x 32	48.6	42.7	1.65	1.65	2.8	2.8	3.0
40 x 25	48.6	34.0	1.65	1.65	2.8	2.8	3.0
40 x 20	48.6	37.2	1.65	1.65	2.8	2.1	3.0
50 x 40	60.5	48.6	1.65	1.65	2.8	2.8	3.5
50 x 32	60.5	42.7	1.65	1.65	2.8	2.8	3.5
50 x 25	60.5	34.0	1.65	1.65	2.8	2.8	3.5
65 x 50	76.3	60.5	2.10	1.65	3.0	2.8	3.5
65 x 40	76.3	48.6	2.10	1.65	3.0	2.8	3.5
65 x 32	76.3	42.7	2.10	1.65	3.0	2.8	3.5
80 x 65	89.1	76.3	2.10	2.10	3.0	3.0	4.0
80 x 50	89.1	60.5	2.10	1.65	3.0	2.8	4.0
80 x 40	89.1	48.6	2.10	1.65	3.0	2.8	4.0
90 x 80	101.6	39.1	2.10	2.10	3.0	3.0	4.0
90 x 65	101.6	76.3	2.10	2.10	3.0	3.0	4.0
90 x 50	101.6	60.5	2.10	1.65	3.0	2.8	4.0
100 x 90	114.3	101.6	2.10	2.10	3.0	3.0	4.0
100 x 80	114.3	89.1	2.10	2.10	3.0	3.0 ^{2/3}	4.0
100 x 65	114.3	76.3	2.10	2.10	3.0	3.0	4.0
100 x 50	114.3	60.5	2.10	1.65	3.0	2.8	4.0

1 | 2